

**Building: Administration Building Lead Results - 2022**

Sample ID	Date/Time Collected	Flushed	Result	Reporting Limit	Method Detection Limit	Analytical Method	Date of Analysis
		(Y/N)	(ug/L)	(ug/L)	(ug/L)		
138 Lunch Rm Sink	2/16/2022 5:33	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
138 Lunch Rm Ice Machine	2/16/2022 5:37	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
162 Basement Water Cooler	2/16/2022 5:40	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
133 Hall Water Cooler	2/16/2022 5:44	N	2.75	2.0	0.66	EPA 200.8	2/22/2022
102 Hall Water Cooler	2/16/2022 5:48	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
112 Lunch Rm Sink	2/16/2022 5:53	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022

**Building: Beeler School Lead Results - 2022**

Sample ID	Date/Time Collected	Flushed	Result	Reporting Limit	Method Detection Limit	Analytical Method	Date of Analysis
		(Y/N)	(ug/L)	(ug/L)	(ug/L)		
182 Library Sink	2/17/2022 4:52	N	1.33	2.0	0.66	200.8	2/22/2022
102 Office Sink	2/17/2022 4:55	N	1.43	2.0	0.66	200.8	2/22/2022
113 Nurse Rm Sink	2/17/2022 4:57	N	<0.66	2.0	0.66	200.8	2/22/2022
111 Teachers Rm Sink	2/17/2022 4:58	N	2.13	2.0	0.66	200.8	2/22/2022
115 Drinking Fountain	2/17/2022 5:00	N	<0.66	2.0	0.66	200.8	2/22/2022
125 Drinking Fountain	2/17/2022 5:02	N	12.7	2.0	0.66	200.8	2/22/2022
116 Drinking Fountain	2/17/2022 5:04	N	0.691	2.0	0.66	200.8	2/22/2022
124 Drinking Fountain	2/17/2022 5:06	N	1.15	2.0	0.66	200.8	2/22/2022
123 Drinking Fountain	2/17/2022 5:07	N	<0.66	2.0	0.66	200.8	2/22/2022
117 Drinking Fountain	2/17/2022 5:09	N	0.744	2.0	0.66	200.8	2/22/2022
118 Drinking Fountain	2/17/2022 5:11	N	<0.66	2.0	0.66	200.8	2/22/2022
119 Drinking Fountain	2/17/2022 5:13	N	0.689	2.0	0.66	200.8	2/22/2022
120 Drinking Fountain	2/17/2022 5:15	N	<0.66	2.0	0.66	200.8	2/22/2022
121 Drinking Fountain	2/17/2022 5:17	N	<0.66	2.0	0.66	200.8	2/22/2022
122 Drinking Fountain	2/17/2022 5:20	N	0.825	2.0	0.66	200.8	2/22/2022
217 Hall Water Cooler	2/17/2022 5:23	N	<0.66	2.0	0.66	200.8	2/22/2022
221 Drinking Fountain	2/17/2022 5:27	N	<0.66	2.0	0.66	200.8	2/22/2022
198 Kitchen Sink - 1	2/17/2022 5:37	N	14.1	2.0	0.66	200.8	2/22/2022
198 Kitchen Sink - 2	2/17/2022 5:38	N	1.48	2.0	0.66	200.8	2/22/2022
198 Kitchen Sink - 3	2/17/2022 5:39	N	6.52	2.0	0.66	200.8	2/22/2022
198 Kitchen Sink - 4	2/17/2022 5:40	N	<0.66	2.0	0.66	200.8	2/22/2022
139 Drinking Fountain	2/17/2022 5:45	N	<0.66	2.0	0.66	200.8	2/22/2022
140 Drinking Fountain	2/17/2022 5:46	N	<0.66	2.0	0.66	200.8	2/22/2022
141 Drinking Fountain	2/17/2022 5:49	N	0.986	2.0	0.66	200.8	2/22/2022
152 Drinking Fountain	2/17/2022 5:53	N	1.01	2.0	0.66	200.8	2/22/2022
153 Drinking Fountain	2/17/2022 5:57	N	1.42	2.0	0.66	200.8	2/22/2022
156 Drinking Fountain	2/17/2022 6:00	N	0.701	2.0	0.66	200.8	2/22/2022
155 Drinking Fountain	2/17/2022 6:02	N	<0.66	2.0	0.66	200.8	2/22/2022
158 Drinking Fountain	2/17/2022 6:04	N	0.710	2.0	0.66	200.8	2/22/2022
157 Drinking Fountain	2/17/2022 6:06	N	<0.66	2.0	0.66	200.8	2/22/2022
160 Drinking Fountain	2/17/2022 6:09	N	0.706	2.0	0.66	200.8	2/22/2022
159 Drinking Fountain	2/17/2022 6:11	N	<0.66	2.0	0.66	200.8	2/22/2022
162 Drinking Fountain	2/17/2022 6:14	N	<0.66	2.0	0.66	200.8	2/22/2022
161 Drinking Fountain	2/17/2022 6:18	N	<0.66	2.0	0.66	200.8	2/22/2022
164 Drinking Fountain	2/17/2022 6:20	N	10.0	2.0	0.66	200.8	2/22/2022
163 Drinking Fountain	2/17/2022 6:22	N	<0.66	2.0	0.66	200.8	2/22/2022
176 Drinking Fountain	2/17/2022 6:25	N	<0.66	2.0	0.66	200.8	2/22/2022
178 Drinking Fountain	2/17/2022 6:27	N	<0.66	2.0	0.66	200.8	2/22/2022
226 Hall Water Cooler - 1	2/17/2022 6:31	N	<0.66	2.0	0.66	200.8	2/22/2022
226 Hall Water Cooler - 2	2/17/2022 6:32	N	<0.66	2.0	0.66	200.8	2/22/2022
179 Drinking Fountain	2/17/2022 6:33	N	<0.66	2.0	0.66	200.8	2/22/2022
180 Drinking Fountain	2/17/2022 6:35	N	<0.66	2.0	0.66	200.8	2/22/2022
181 Drinking Fountain	2/17/2022 6:36	N	<0.66	2.0	0.66	200.8	2/22/2022

Building: Demasi School Lead Results - 2022							
Sample ID	Date/Time Collected	Flushed (Y/N)	Result (ug/L)	Reporting Limit (ug/L)	Method Detection Limit (ug/L)	Analytical Method	Date of Analysis
525 Water Cooler	2/18/2022 4:01	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
519 Hall Water Cooler	2/18/2022 4:03	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
515 Hall Water Cooler	2/18/2022 4:04	N	1.34	2.0	0.66	EPA 200.8	2/22/2022
513 Hall Water Cooler	2/18/2022 4:07	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
562 Hall Water Cooler -1	2/18/2022 4:08	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
562 Hall Water Cooler -2	2/18/2022 4:10	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
562 Hall Water Cooler -3	2/18/2022 4:11	N	1.92	2.0	0.66	EPA 200.8	2/22/2022
508 Home Ec Sink -1	2/18/2022 4:15	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
508 Home Ec Sink -2	2/18/2022 4:16	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
508 Home Ec Sink -3	2/18/2022 4:17	N	1.15	2.0	0.66	EPA 200.8	2/22/2022
508 Home Ec Sink -4	2/18/2022 4:19	N	0.938	2.0	0.66	EPA 200.8	2/22/2022
508 Home Ec Sink -5	2/18/2022 4:20	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
508 Home Ec Sink -6	2/18/2022 4:21	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
504 Drinking Fountain	2/18/2022 4:24	N	2.82	2.0	0.66	EPA 200.8	2/22/2022
539 Ice Machine	2/18/2022 4:32	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
544 Server Rm Sink	2/18/2022 4:34	N	1.11	2.0	0.66	EPA 200.8	2/22/2022
542 Server Rm Sink	2/18/2022 4:37	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
546 Kitchen Sink	2/18/2022 4:38	N	1.02	2.0	0.66	EPA 200.8	2/22/2022
541 Kitchen Sink - 1	2/18/2022 4:41	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
541 Kitchen Sink - 2	2/18/2022 4:42	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
540 Server Rm Sink	2/18/2022 4:44	N	2.85	2.0	0.66	EPA 200.8	2/22/2022
536 Server Rm Sink	2/18/2022 4:47	N	1.58	2.0	0.66	EPA 200.8	2/22/2022
417 Hall Water Cooler	2/18/2022 4:51	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
414 Teacher Lunch Rm Sink	2/18/2022 4:53	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
428 Hall Water Cooler	2/18/2022 4:55	N	2.82	2.0	0.66	EPA 200.8	2/22/2022
431 Hall Water Cooler	2/18/2022 4:57	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
413 Hall Water Cooler	2/18/2022 5:02	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
304 Office Rm Sink	2/18/2022 5:12	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
408 Nurse Rm Sink	2/18/2022 5:14	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
404 Office Rm Sink	2/18/2022 5:15	N	---	2.0	0.66	EPA 200.8	---
404 Office Rm Sink	2/24/2022 6:20	N	<0.66	2.0	0.66	EPA 200.8	3/2/2022
204 Office Rm Sink	2/18/2022 5:17	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
104 Office Rm Sink	2/18/2022 5:21	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
107 Drinking Fountain	2/18/2022 5:24	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
107 Hall Water Cooler	2/18/2022 5:26	N	1.35	2.0	0.66	EPA 200.8	2/22/2022
116 Hall Water Cooler	2/18/2022 5:26	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
119 Hall Water Cooler	2/18/2022 5:29	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
126 Hall Water Cooler	2/18/2022 5:31	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
108 Drinking Fountain	2/18/2022 5:34	N	1.35	2.0	0.66	EPA 200.8	2/22/2022
109 Drinking Fountain	2/18/2022 5:36	N	2.28	2.0	0.66	EPA 200.8	2/22/2022
110 Drinking Fountain	2/18/2022 5:37	N	1.14	2.0	0.66	EPA 200.8	2/22/2022
111 Drinking Fountain	2/18/2022 5:38	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
112 Drinking Fountain	2/18/2022 5:39	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
113 Drinking Fountain	2/18/2022 5:41	N	0.888	2.0	0.66	EPA 200.8	2/22/2022
114 Drinking Fountain	2/18/2022 5:42	N	0.667	2.0	0.66	EPA 200.8	2/22/2022
115 Drinking Fountain	2/18/2022 5:43	N	1.19	2.0	0.66	EPA 200.8	2/22/2022
116 Drinking Fountain	2/18/2022 5:45	N	3.52	2.0	0.66	EPA 200.8	2/22/2022
117 Drinking Fountain	2/18/2022 5:46	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
126 Drinking Fountain	2/18/2022 5:50	N	4.95	2.0	0.66	EPA 200.8	2/22/2022
127 Drinking Fountain	2/18/2022 5:51	N	1.88	2.0	0.66	EPA 200.8	2/22/2022
128 Drinking Fountain	2/18/2022 5:54	N	3.06	2.0	0.66	EPA 200.8	2/22/2022
129 Drinking Fountain	2/18/2022 5:55	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
132 Drinking Fountain	2/18/2022 5:56	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
133 Drinking Fountain	2/18/2022 5:58	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
134 Drinking Fountain	2/18/2022 6:04	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
136 Drinking Fountain	2/18/2022 6:08	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
137 Drinking Fountain	2/18/2022 6:09	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
140 Drinking Fountain	2/18/2022 6:11	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
141 Drinking Fountain	2/18/2022 6:13	N	1.33	2.0	0.66	EPA 200.8	2/22/2022
207 Hall Water Cooler	2/18/2022 6:16	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
216 Hall Water Cooler	2/18/2022 6:17	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
219 Hall Water Cooler	2/18/2022 6:18	N	<0.66	2.0	0.66	EPA 200.8	2/22/2022
226 Hall Water Cooler	2/18/2022 6:19	N	1.74	2.0	0.66	EPA 200.8	2/22/2022
307 Hall Water Cooler	2/18/2022 6:23	N	0.017	2.0	0.66	EPA 200.8	2/23/2022
316 Hall Water Cooler	2/18/2022 6:24	N	<0.66	2.0	0.66	EPA 200.8	2/23/2022
319 Hall Water Cooler	2/18/2022 6:26	N	2.41	2.0	0.66	EPA 200.8	2/23/2022
326 Hall Water Cooler	2/18/2022 6:28	N	<0.66	2.0	0.66	EPA 200.8	2/23/2022

**Building: Jaggard Elementary School Lead Results - 2022**

Sample ID	Date/Time Collected	Flushed (Y/N)	Result (ug/L)	Reporting Limit (ug/L)	Method Detection Limit (ug/L)	Analytical Method	Date of Analysis
238 Hall Water Cooler - 1	2/25/2022 4:21	N	<0.66	2.0	0.66	EPA 200.8	3/4/2022
238 Hall Water Cooler - 2	2/25/2022 4:22	N	<0.66	2.0	0.66	EPA 200.8	3/4/2022
115 Teachers Rm Sink	2/25/2022 4:24	N	<0.66	2.0	0.66	EPA 200.8	3/4/2022
158 Teachers Rm Sink	2/25/2022 4:26	N	1.5	2.0	0.66	EPA 200.8	3/4/2022
100 Office Water Cooler	2/25/2022 4:28	N	8.76	2.0	0.66	EPA 200.8	3/4/2022
107 Nurse Sink	2/25/2022 4:30	N	0.85	2.0	0.66	EPA 200.8	3/4/2022
169 Drinking Fountain	2/25/2022 4:32	N	1.01	2.0	0.66	EPA 200.8	3/4/2022
166 Drinking Fountain	2/25/2022 4:34	N	<0.66	2.0	0.66	EPA 200.8	3/4/2022
171 Drinking Fountain	2/25/2022 4:36	N	1.34	2.0	0.66	EPA 200.8	3/4/2022
168 Drinking Fountain	2/25/2022 4:37	N	0.904	2.0	0.66	EPA 200.8	3/4/2022
173 Drinking Fountain	2/25/2022 4:39	N	1.11	2.0	0.66	EPA 200.8	3/4/2022
170 Drinking Fountain	2/25/2022 4:40	N	<0.66	2.0	0.66	EPA 200.8	3/4/2022
174 Drinking Fountain	2/25/2022 4:42	N	20.9	2.0	0.66	EPA 200.8	3/4/2022
175 Drinking Fountain	2/25/2022 4:43	N	0.747	2.0	0.66	EPA 200.8	3/4/2022
177 Drinking Fountain	2/25/2022 4:47	N	<0.66	2.0	0.66	EPA 200.8	3/4/2022
178 Drinking Fountain	2/25/2022 4:49	N	0.73	2.0	0.66	EPA 200.8	3/4/2022
179 Drinking Fountain	2/25/2022 4:51	N	1.41	2.0	0.66	EPA 200.8	3/4/2022
180 Drinking Fountain	2/25/2022 4:54	N	4.34	2.0	0.66	EPA 200.8	3/4/2022
181 Drinking Fountain	2/25/2022 4:56	N	1.22	2.0	0.66	EPA 200.8	3/4/2022
249 Water Cooler	2/25/2022 4:57	N	22.9	2.0	0.66	EPA 200.8	3/4/2022
164 Drinking Fountain	2/25/2022 4:59	N	2.17	2.0	0.66	EPA 200.8	3/4/2022
162 Drinking Fountain	2/25/2022 5:01	N	1.69	2.0	0.66	EPA 200.8	3/4/2022
161 Drinking Fountain	2/25/2022 5:02	N	7.39	2.0	0.66	EPA 200.8	3/4/2022
160 Drinking Fountain	2/25/2022 5:04	N	0.841	2.0	0.66	EPA 200.8	3/7/2022
165 Water Cooler - 1	2/25/2022 5:05	N	<0.66	2.0	0.66	EPA 200.8	3/7/2022
165 Water Cooler - 2	2/25/2022 5:06	N	1.04	2.0	0.66	EPA 200.8	3/7/2022
156 Drinking Fountain	2/25/2022 5:08	N	13.8	2.0	0.66	EPA 200.8	3/7/2022
154 Drinking Fountain	2/25/2022 5:10	N	2.23	2.0	0.66	EPA 200.8	3/7/2022
155 Drinking Fountain	2/25/2022 5:11	N	3.53	2.0	0.66	EPA 200.8	3/7/2022
122 Drinking Fountain	2/25/2022 5:18	N	0.972	2.0	0.66	EPA 200.8	3/7/2022
121 Drinking Fountain	2/25/2022 5:20	N	1.95	2.0	0.66	EPA 200.8	3/7/2022
120 Drinking Fountain	2/25/2022 5:22	N	1.37	2.0	0.66	EPA 200.8	3/7/2022
119 Drinking Fountain	2/25/2022 5:24	N	0.818	2.0	0.66	EPA 200.8	3/7/2022
117 Kitchen Sink - 1	2/25/2022 5:26	N	4.61	2.0	0.66	EPA 200.8	3/7/2022
117 Kitchen Sink - 2	2/25/2022 5:27	N	0.92	2.0	0.66	EPA 200.8	3/7/2022
117 Kitchen Sink - 3	2/25/2022 5:28	N	1.09	2.0	0.66	EPA 200.8	3/7/2022
148 Drinking Fountain	2/25/2022 5:33	N	<0.66	2.0	0.66	EPA 200.8	3/7/2022
142 Drinking Fountain	2/25/2022 5:36	N	<0.66	2.0	0.66	EPA 200.8	3/7/2022
147 Drinking Fountain	2/25/2022 5:38	N	<0.66	2.0	0.66	EPA 200.8	3/7/2022
146 Drinking Fountain	2/25/2022 5:40	N	<0.66	2.0	0.66	EPA 200.8	3/7/2022
145 Drinking Fountain	2/25/2022 5:42	N	<0.66	2.0	0.66	EPA 200.8	3/7/2022
143 Drinking Fountain	2/25/2022 5:45	N	<0.66	2.0	0.66	EPA 200.8	3/7/2022
149 Drinking Fountain	2/25/2022 5:47	N	<0.66	2.0	0.66	EPA 200.8	3/7/2022
150 Drinking Fountain	2/25/2022 5:49	N	1.13	2.0	0.66	EPA 200.8	3/7/2022
153 Drinking Fountain	2/25/2022 5:52	N	<0.66	2.0	0.66	EPA 200.8	3/7/2022
243 Hall Water Cooler - 1	2/25/2022 5:54	N	4.52	2.0	0.66	EPA 200.8	3/7/2022
244 Hall Water Cooler - 2	2/25/2022 5:56	N	<0.66	2.0	0.66	EPA 200.8	3/7/2022
245 Hall Water Cooler - 3	2/25/2022 5:57	N	<0.66	2.0	0.66	EPA 200.8	3/7/2022
246 Hall Water Cooler - 4	2/25/2022 6:01	N	<0.66	2.0	0.66	EPA 200.8	3/7/2022

**Building: Evans Elementary School Lead Results - 2022**

Sample ID	Date/Time Collected	Flushed (Y/N)	Result (ug/L)	Reporting Limit (ug/L)	Method Detection Limit (ug/L)	Analytical Method	Date of Analysis
121 Drinking Fountain	2/24/2022 4:48	N	5.08	2.0	0.66	EPA 200.8	3/2/2022
121 Lunch Room Sinks- 1	2/24/2022 4:50	N	3.66	2.0	0.66	EPA 200.8	3/2/2022
121 Lunch Room Sinks- 2	2/24/2022 4:51	N	3.63	2.0	0.66	EPA 200.8	3/2/2022
119 Drinking Fountain	2/24/2022 4:52	N	1.45	2.0	0.66	EPA 200.8	3/2/2022
213 Hall Water Cooler -1	2/24/2022 4:53	N	<0.66	2.0	0.66	EPA 200.8	3/2/2022
213 Hall Water Cooler -2	2/24/2022 4:54	N	<0.66	2.0	0.66	EPA 200.8	3/2/2022
140 Hall Drinking Fountain	2/24/2022 4:58	N	3.36	2.0	0.66	EPA 200.8	3/2/2022
141 Drinking Fountain	2/24/2022 5:02	N	4.59	2.0	0.66	EPA 200.8	3/2/2022
142 Drinking Fountain	2/24/2022 5:04	N	0.807	2.0	0.66	EPA 200.8	3/2/2022
216 Hall Water Cooler -1	2/24/2022 5:07	N	<0.66	2.0	0.66	EPA 200.8	3/2/2022
216 Hall Water Cooler -2	2/24/2022 5:09	N	<0.66	2.0	0.66	EPA 200.8	3/2/2022
149 Drinking Fountain	2/24/2022 5:11	N	<0.66	2.0	0.66	EPA 200.8	3/2/2022
152 Drinking Fountain	2/24/2022 5:12	N	<0.66	2.0	0.66	EPA 200.8	3/2/2022
150 Drinking Fountain	2/24/2022 5:13	N	<0.66	2.0	0.66	EPA 200.8	3/2/2022
151 Drinking Fountain	2/24/2022 5:15	N	<0.66	2.0	0.66	EPA 200.8	3/2/2022
217 Hall Drinking Fountain - 1	2/24/2022 5:17	N	14.8	2.0	0.66	EPA 200.8	3/2/2022
156 Drinking Fountain	2/24/2022 5:19	N	9.19	2.0	0.66	EPA 200.8	3/2/2022
217 Hall Drinking Fountain - 2	2/24/2022 5:24	N	5.56	2.0	0.66	EPA 200.8	3/2/2022
217 Hall Drinking Fountain - 3	2/24/2022 5:26	N	6.40	2.0	0.66	EPA 200.8	3/2/2022
201 Ice Machine	2/24/2022 5:29	N	<0.66	2.0	0.66	EPA 200.8	3/4/2022
200 Kitchen Sink - 1	2/24/2022 5:33	N	4.22	2.0	0.66	EPA 200.8	3/4/2022
200 Kitchen Sink - 2	2/24/2022 5:34	N	5.88	2.0	0.66	EPA 200.8	3/4/2022
200 Kitchen Sink - 3	2/24/2022 5:36	N	<0.66	2.0	0.66	EPA 200.8	3/4/2022
200 Steam Kettle	2/24/2022 5:37	N	<0.66	2.0	0.66	EPA 200.8	3/4/2022
205 Water Cooler	2/24/2022 5:41	N	<0.66	2.0	0.66	EPA 200.8	3/4/2022
218 Drinking Fountain - 1	2/24/2022 5:44	N	1.52	2.0	0.66	EPA 200.8	3/4/2022
218 Drinking Fountain - 2	2/24/2022 5:45	N	3.98	2.0	0.66	EPA 200.8	3/4/2022
169 Drinking Fountain	2/24/2022 5:47	N	6.05	2.0	0.66	EPA 200.8	3/4/2022
176 Kitchen Sink	2/24/2022 5:49	N	0.819	2.0	0.66	EPA 200.8	3/4/2022
110 Drinking Fountain	2/24/2022 5:54	N	2.86	2.0	0.66	EPA 200.8	3/4/2022
112 Drinking Fountain	2/24/2022 5:56	N	18.4	2.0	0.66	EPA 200.8	3/4/2022
113 Drinking Fountain	2/24/2022 5:58	N	1.72	2.0	0.66	EPA 200.8	3/4/2022
115 Drinking Fountain	2/24/2022 6:00	N	45.2	2.0	0.66	EPA 200.8	3/4/2022
114 Drinking Fountain	2/24/2022 6:03	N	8.08	2.0	0.66	EPA 200.8	3/4/2022
109 Nurses Sink	2/24/2022 6:06	N	<0.66	2.0	0.66	EPA 200.8	3/4/2022
109 Water Cooler	2/24/2022 6:07	N	<0.66	2.0	0.66	EPA 200.8	3/4/2022

**Building: Marlton Elementary School Lead Results - 2022**

Sample ID	Date/Time Collected	Flushed (Y/N)	Result (ug/L)	Reporting Limit (ug/L)	Method Detection Limit (ug/L)	Analytical Method	Date of Analysis
159 Kitchen Sink - 1	3/2/2022 4:42	N	27.8	2.0	0.66	EPA 200.8	3/11/2022
159 Kitchen Sink - 2	3/2/2022 4:43	N	35.8	2.0	0.66	EPA 200.8	3/11/2022
159 Kitchen Sink - 3	3/2/2022 4:44	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
159 Kitchen Sink - 4	3/2/2022 4:45	N	1.91	2.0	0.66	EPA 200.8	3/11/2022
180 Hall Water Cooler	3/2/2022 4:48	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
110 Nurse Rm Sink	3/2/2022 4:49	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
104 Office Rm Sink	3/2/2022 4:50	N	0.828	2.0	0.66	EPA 200.8	3/11/2022
107 Teachers Lunch Rm Sink	3/2/2022 4:52	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
178 Hall Water Cooler - 1	3/2/2022 4:53	N	1.05	2.0	0.66	EPA 200.8	3/11/2022
179 Hall Water Cooler - 2	3/2/2022 4:54	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
126 Drinking Fountain	3/2/2022 4:58	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
127 Drinking Fountain	3/2/2022 4:59	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
129 Drinking Fountain	3/2/2022 5:00	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
128 Drinking Fountain	3/2/2022 5:02	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
134 Drinking Fountain	3/2/2022 5:03	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
137 Drinking Fountain	3/2/2022 5:05	N	12.1	2.0	0.66	EPA 200.8	3/11/2022
140 Drinking Fountain	3/2/2022 5:07	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
139 Drinking Fountain	3/2/2022 5:10	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
143 Drinking Fountain	3/2/2022 5:11	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
142 Drinking Fountain	3/2/2022 5:12	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
144 Drinking Fountain	3/2/2022 5:13	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
145 Drinking Fountain	3/2/2022 5:15	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
146 Drinking Fountain	3/2/2022 5:16	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
147 Drinking Fountain	3/2/2022 5:17	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
150 Hall Water Cooler - 1	3/2/2022 5:19	N	1.07	2.0	0.66	EPA 200.8	3/11/2022
150 Hall Water Cooler - 2	3/2/2022 5:21	N	5.1	2.0	0.66	EPA 200.8	3/11/2022
186 Hall Water Cooler - 1	3/2/2022 5:26	N	2.33	2.0	0.66	EPA 200.8	3/11/2022
186 Hall Water Cooler - 2	3/2/2022 5:27	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
202 Drinking Fountain	3/2/2022 5:33	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
203 Drinking Fountain	3/2/2022 5:34	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
205 Drinking Fountain	3/2/2022 5:35	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
204 Drinking Fountain	3/2/2022 5:37	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
206 Drinking Fountain	3/2/2022 5:39	N	4.57	2.0	0.66	EPA 200.8	3/11/2022
208 Drinking Fountain	3/2/2022 5:42	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
216 Drinking Fountain	3/2/2022 5:45	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
218 Drinking Fountain	3/2/2022 5:47	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
219 Drinking Fountain	3/2/2022 5:48	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
220 Drinking Fountain	3/2/2022 5:49	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
323 Hall Water Cooler	3/2/2022 5:52	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
221 Drinking Fountain	3/2/2022 5:53	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
222 Drinking Fountain	3/2/2022 5:55	N	3.78	2.0	0.66	EPA 200.8	3/11/2022
223 Drinking Fountain	3/2/2022 5:56	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022

**Building: Marlton Middle School Lead Results - 2022**

Sample ID	Date/Time Collected	Flushed (Y/N)	Result (ug/L)	Reporting Limit (ug/L)	Method Detection Limit (ug/L)	Analytical Method	Date of Analysis
353 Kitchen Sink Three Bay Faucet - 1	3/3/2022 4:23	N	3.58	2.0	0.66	EPA 200.8	3/9/2022
353 Kitchen Sink Three Bay Faucet - 2	3/3/2022 4:24	N	2.48	2.0	0.66	EPA 200.8	3/9/2022
353 Island Sink - 1	3/3/2022 4:25	N	0.672	2.0	0.66	EPA 200.8	3/9/2022
353 Steam Kettle	3/3/2022 4:26	N	0.934	2.0	0.66	EPA 200.8	3/9/2022
322 ICE Machine - Kitchen	3/3/2022 4:28	N	<0.66	2.0	0.66	EPA 200.8	3/9/2022
<b>322 Hall APR Water Cooler - 1</b>	<b>3/3/2022 4:30</b>	<b>N</b>	<b>63.6</b>	2.0	0.66	EPA 200.8	3/9/2022
<b>323 Hall APR Water Cooler - 2</b>	<b>3/3/2022 4:32</b>	<b>N</b>	<b>319</b>	2.0	0.66	EPA 200.8	3/9/2022
<b>324 Hall APR Water Cooler - 3</b>	<b>3/3/2022 4:33</b>	<b>N</b>	<b>251</b>	2.0	0.66	EPA 200.8	3/9/2022
<b>325 Hall APR Water Cooler - 4</b>	<b>3/3/2022 4:34</b>	<b>N</b>	<b>47.4</b>	2.0	0.66	EPA 200.8	3/9/2022
346 Shop Sink & Fountain	3/3/2022 4:36	N	1.89	2.0	0.66	EPA 200.8	3/9/2022
341 Shop Sink & Fountain	3/3/2022 4:38	N	2.86	2.0	0.66	EPA 200.8	3/9/2022
312 Hall Water Cooler - 1	3/3/2022 4:40	N	8.03	2.0	0.66	EPA 200.8	3/9/2022
313 Hall Water Cooler - 2	3/3/2022 4:42	N	6.54	2.0	0.66	EPA 200.8	3/9/2022
314 Hall Water Cooler - 3	3/3/2022 4:43	N	1.9	2.0	0.66	EPA 200.8	3/9/2022
310 Teacher Lunch RM Sink	3/3/2022 4:45	N	1.16	2.0	0.66	EPA 200.8	3/9/2022
416 Home Cooking Sink	3/3/2022 4:48	N	3.77	2.0	0.66	EPA 200.8	3/9/2022
414 Home Cooking Sink - 1	3/3/2022 4:49	N	<0.66	2.0	0.66	EPA 200.8	3/9/2022
414 Home Cooking Sink - 2	3/3/2022 4:50	N	1.43	2.0	0.66	EPA 200.8	3/9/2022
414 Home Cooking Sink - 3	3/3/2022 4:53	N	2.14	2.0	0.66	EPA 200.8	3/9/2022
414 Home Cooking Sink - 4	3/3/2022 4:55	N	4.95	2.0	0.66	EPA 200.8	3/9/2022
414 Home Cooking Sink - 5	3/3/2022 4:56	N	5.67	2.0	0.66	EPA 200.8	3/10/2022
403 Main Office Water Cooler	3/3/2022 4:59	N	2.47	2.0	0.66	EPA 200.8	3/10/2022
200 Teacher Lunch Rm Sink	3/3/2022 5:04	N	0.702	2.0	0.66	EPA 200.8	3/10/2022
202 Hall Water Coolers - 1	3/3/2022 5:06	N	<0.66	2.0	0.66	EPA 200.8	3/10/2022
203 Hall Water Coolers - 2	3/3/2022 5:07	N	0.952	2.0	0.66	EPA 200.8	3/10/2022
204 Hall Water Coolers - 3	3/3/2022 5:08	N	1.44	2.0	0.66	EPA 200.8	3/10/2022
205 Hall Water Coolers - 4	3/3/2022 5:09	N	<0.66	2.0	0.66	EPA 200.8	3/10/2022
144 Hall Water Cooler - 1	3/3/2022 5:16	N	<0.66	2.0	0.66	EPA 200.8	3/10/2022
144 Hall Water Cooler - 2	3/3/2022 5:17	N	11.7	2.0	0.66	EPA 200.8	3/10/2022
144 Hall Water Cooler - 3	3/3/2022 5:18	N	1.75	2.0	0.66	EPA 200.8	3/10/2022
144 Hall Water Cooler - 4	3/3/2022 5:19	N	2.44	2.0	0.66	EPA 200.8	3/10/2022
<b>156 Gym Water Fountain Girls</b>	<b>3/3/2022 5:23</b>	<b>N</b>	<b>17.9</b>	2.0	0.66	EPA 200.8	3/10/2022
162 Gym Water Fountain Boys	3/3/2022 5:26	N	0.872	2.0	0.66	EPA 200.8	3/10/2022
125 Hall Water Cooler -1	3/3/2022 5:28	N	2.38	2.0	0.66	EPA 200.8	3/10/2022
126 Hall Water Cooler -2	3/3/2022 5:29	N	7.1	2.0	0.66	EPA 200.8	3/10/2022
127 Hall Water Cooler -3	3/3/2022 5:31	N	1.51	2.0	0.66	EPA 200.8	3/10/2022
128 Hall Water Cooler -4	3/3/2022 5:32	N	1.82	2.0	0.66	EPA 200.8	3/10/2022
129 Hall Water Cooler -5	3/3/2022 5:33	N	0.837	2.0	0.66	EPA 200.8	3/10/2022
122 Teacher lunch Rm Sink	3/3/2022 5:34	N	2.42	2.0	0.66	EPA 200.8	3/10/2022
407 Nurses Rm Sink	3/3/2022 5:36	N	1.83	2.0	0.66	EPA 200.8	3/10/2022
407 Nurses Rm Toilet Rm Sink	3/3/2022 5:39	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
402 Work Rm Sink	3/3/2022 5:41	N	0.88	2.0	0.66	EPA 200.8	3/11/2022
109 TBA - Rm Sink	3/3/2022 5:48	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
117 TBA - Rm Sink	3/3/2022 5:51	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
109 Hall Water Cooler - 1	3/3/2022 5:52	N	1.56	2.0	0.66	EPA 200.8	3/11/2022
109 Hall Water Cooler - 2	3/3/2022 5:54	N	2.48	2.0	0.66	EPA 200.8	3/11/2022
110 TBA - Rm Sink	3/3/2022 5:58	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
116 TBA - Rm Sink	3/3/2022 5:59	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
111 TBA - Rm Sink	3/3/2022 6:01	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
114 TBA - Rm Sink	3/3/2022 6:03	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022
112 TBA - Rm Sink	3/3/2022 6:04	N	<0.66	2.0	0.66	EPA 200.8	3/11/2022

**Building: Rice Elementary School Lead Results - 2022**

Sample ID	Date/Time Collected	Flushed	Result	Reporting Limit	Method Detection Limit	Analytical Method	Date of Analysis
		(Y/N)	(ug/L)	(ug/L)	(ug/L)		
208 Kitchen Sink - 1	3/9/2022 4:14	N	2.27	2.0	0.66	EPA 200.8	3/20/2022
208 Kitchen Sink - 2	3/9/2022 4:16	N	<0.66	2.0	0.66	EPA 200.8	3/20/2022
208 Kitchen Sink - 3	3/9/2022 4:17	N	9.98	2.0	0.66	EPA 200.8	3/20/2022
208 Kitchen Sink - 4	3/9/2022 4:18	N	7.54	2.0	0.66	EPA 200.8	3/20/2022
225 Hall Water Cooler - 1	3/9/2022 4:21	N	<0.66	2.0	0.66	EPA 200.8	3/20/2022
225 Hall Water Cooler - 2	3/9/2022 4:22	N	<0.66	2.0	0.66	EPA 200.8	3/20/2022
212 Custodial Office Rm Sink	3/9/2022 4:26	N	1.82	2.0	0.66	EPA 200.8	3/20/2022
213 Drinking Fountain	3/9/2022 4:29	N	8.25	2.0	0.66	EPA 200.8	3/20/2022
Teachers Rm Sink	3/9/2022 4:30	N	<0.66	2.0	0.66	EPA 200.8	3/20/2022
168 Drinking Fountain	3/9/2022 4:33	N	1.98	2.0	0.66	EPA 200.8	3/20/2022
167 Drinking Fountain	3/9/2022 4:35	N	1.99	2.0	0.66	EPA 200.8	3/20/2022
166 Drinking Fountain	3/9/2022 4:36	N	8.9	2.0	0.66	EPA 200.8	3/20/2022
165 Drinking Fountain	3/9/2022 4:37	N	3.37	2.0	0.66	EPA 200.8	3/20/2022
164 Drinking Fountain	3/9/2022 4:39	N	2.23	2.0	0.66	EPA 200.8	3/20/2022
163 Drinking Fountain	3/9/2022 4:40	N	3.43	2.0	0.66	EPA 200.8	3/20/2022
162 Drinking Fountain	3/9/2022 4:42	N	3.73	2.0	0.66	EPA 200.8	3/20/2022
161 Drinking Fountain	3/9/2022 4:43	N	9.93	2.0	0.66	EPA 200.8	3/20/2022
160 Drinking Fountain	3/9/2022 4:46	N	3.39	2.0	0.66	EPA 200.8	3/20/2022
159 Drinking Fountain	3/9/2022 4:48	N	1.6	2.0	0.66	EPA 200.8	3/20/2022
152 Drinking Fountain	3/9/2022 4:53	N	<0.66	2.0	0.66	EPA 200.8	3/20/2022
220 Hall Water Cooler - 1	3/9/2022 4:54	N	0.739	2.0	0.66	EPA 200.8	3/20/2022
220 Hall Water Cooler - 2	3/9/2022 4:56	N	<0.66	2.0	0.66	EPA 200.8	3/20/2022
141 Drinking Fountain	3/9/2022 4:57	N	<0.66	2.0	0.66	EPA 200.8	3/20/2022
152 Drinking Fountain	3/9/2022 5:02	N	<0.66	2.0	0.66	EPA 200.8	3/20/2022
151 Drinking Fountain	3/9/2022 5:03	N	<0.66	2.0	0.66	EPA 200.8	3/20/2022
142 Drinking Fountain	3/9/2022 5:05	N	<0.66	2.0	0.66	EPA 200.8	3/20/2022
143 Drinking Fountain	3/9/2022 5:06	N	<0.66	2.0	0.66	EPA 200.8	3/20/2022
144 Drinking Fountain	3/9/2022 5:09	N	<0.66	2.0	0.66	EPA 200.8	3/20/2022
146 Drinking Fountain	3/9/2022 5:11	N	<0.66	2.0	0.66	EPA 200.8	3/20/2022
145 Drinking Fountain	3/9/2022 5:12	N	<0.66	2.0	0.66	EPA 200.8	3/20/2022
138 Drinking Fountain	3/9/2022 5:19	N	1.22	2.0	0.66	EPA 200.8	3/20/2022
137 Drinking Fountain	3/9/2022 5:20	N	0.69	2.0	0.66	EPA 200.8	3/20/2022
136 Drinking Fountain	3/9/2022 5:23	N	2.37	2.0	0.66	EPA 200.8	3/20/2022
135 Drinking Fountain	3/9/2022 5:25	N	3.74	2.0	0.66	EPA 200.8	3/20/2022
129 Drinking Fountain	3/9/2022 5:34	N	3.79	2.0	0.66	EPA 200.8	3/20/2022
127 Drinking Fountain	3/9/2022 5:36	N	1.02	2.0	0.66	EPA 200.8	3/20/2022
126 Drinking Fountain	3/9/2022 5:37	N	2.62	2.0	0.66	EPA 200.8	3/20/2022
125 Drinking Fountain	3/9/2022 5:39	N	4.17	2.0	0.66	EPA 200.8	3/20/2022
124 Drinking Fountain	3/9/2022 5:40	N	1.61	2.0	0.66	EPA 200.8	3/20/2022
123 Drinking Fountain	3/9/2022 5:42	N	1.03	2.0	0.66	EPA 200.8	3/20/2022
122 Drinking Fountain	3/9/2022 5:43	N	1.58	2.0	0.66	EPA 200.8	3/20/2022
121 Drinking Fountain	3/9/2022 5:44	N	1.3	2.0	0.66	EPA 200.8	3/20/2022
120 Drinking Fountain	3/9/2022 5:47	N	2.35	2.0	0.66	EPA 200.8	3/20/2022
216 Hall Water Cooler	3/9/2022 5:49	N	<0.66	2.0	0.66	EPA 200.8	3/20/2022
111 Library Drinking Fountain	3/9/2022 5:53	N	10.8	2.0	0.66	EPA 200.8	3/20/2022
113 Drinking Fountain	3/9/2022 5:56	N	5.32	2.0	0.66	EPA 200.8	3/20/2022
114 Drinking Fountain	3/9/2022 5:57	N	2.37	2.0	0.66	EPA 200.8	3/20/2022
109 Nurse Rm Sink	3/9/2022 6:00	N	<0.66	2.0	0.66	EPA 200.8	3/20/2022
105 Office Rm Sink	3/9/2022 6:02	N	<0.66	2.0	0.66	EPA 200.8	3/20/2022
115 Drinking Fountain	3/9/2022 6:05	N	<0.66	2.0	0.66	EPA 200.8	3/20/2022



**Building: Van Zant Elementary School Lead Results - 2022**

Sample ID	Date/Time Collected	Flushed	Result	Reporting Limit	Method Detection Limit	Analytical Method	Date of Analysis
		(Y/N)	(ug/L)	(ug/L)	(ug/L)		
187 Kitchen Sink - 1	3/10/2022 4:19	N	0.904	2.0	0.66	EPA 200.8	3/20/2022
187 Kitchen Sink - 2	3/10/2022 4:20	N	1.94	2.0	0.66	EPA 200.8	3/20/2022
187 Kitchen Sink - 3	3/10/2022 4:21	N	<0.66	2.0	0.66	EPA 200.8	3/20/2022
187 Kitchen Sink - 4	3/10/2022 4:23	N	0.768	2.0	0.66	EPA 200.8	3/20/2022
188 Teacher Lunch Rm	3/10/2022 4:25	N	1.56	2.0	0.66	EPA 200.8	3/20/2022
205 Hall Water Cooler - 1	3/10/2022 4:29	N	1.93	2.0	0.66	EPA 200.8	3/20/2022
205 Hall Water Cooler - 2	3/10/2022 4:30	N	<0.66	2.0	0.66	EPA 200.8	3/20/2022
106 Nurse Rm Sink	3/10/2022 4:31	N	<0.66	2.0	0.66	EPA 200.8	3/20/2022
169 Drinking Fountain	3/10/2022 4:33	N	2.06	2.0	0.66	EPA 200.8	3/20/2022
167 Drinking Fountain	3/10/2022 4:35	N	4.85	2.0	0.66	EPA 200.8	3/20/2022
164 Drinking Fountain	3/10/2022 4:38	N	2.05	2.0	0.66	EPA 200.8	3/20/2022
165 Drinking Fountain	3/10/2022 4:39	N	1.43	2.0	0.66	EPA 200.8	3/20/2022
163 Drinking Fountain	3/10/2022 4:41	N	1.36	2.0	0.66	EPA 200.8	3/20/2022
162 Drinking Fountain	3/10/2022 4:42	N	1.07	2.0	0.66	EPA 200.8	3/20/2022
161 Drinking Fountain	3/10/2022 4:44	N	2.17	2.0	0.66	EPA 200.8	3/20/2022
160 Drinking Fountain	3/10/2022 4:46	N	3.59	2.0	0.66	EPA 200.8	3/20/2022
157 Drinking Fountain	3/10/2022 4:47	N	5.88	2.0	0.66	EPA 200.8	3/20/2022
159 Drinking Fountain	3/10/2022 4:49	N	2.41	2.0	0.66	EPA 200.8	3/20/2022
154 Drinking Fountain	3/10/2022 4:51	N	1.60	2.0	0.66	EPA 200.8	3/20/2022
153 Drinking Fountain	3/10/2022 4:53	N	<0.66	2.0	0.66	EPA 200.8	3/20/2022
152 Drinking Fountain	3/10/2022 4:55	N	<0.66	2.0	0.66	EPA 200.8	3/20/2022
151 Drinking Fountain	3/10/2022 4:56	N	<0.66	2.0	0.66	EPA 200.8	3/20/2022
147 Drinking Fountain	3/10/2022 4:58	N	<0.66	2.0	0.66	EPA 200.8	3/20/2022
145 Drinking Fountain	3/10/2022 5:01	N	<0.66	2.0	0.66	EPA 200.8	3/20/2022
143 Drinking Fountain	3/10/2022 5:03	N	1.21	2.0	0.66	EPA 200.8	3/20/2022
141 Drinking Fountain	3/10/2022 5:05	N	<0.66	2.0	0.66	EPA 200.8	3/20/2022
117 Drinking Fountain	3/10/2022 5:14	N	9.24	2.0	0.66	EPA 200.8	3/20/2022
114 Drinking Fountain	3/10/2022 5:16	N	2.73	2.0	0.66	EPA 200.8	3/20/2022
112 Drinking Fountain	3/10/2022 5:18	N	1.73	2.0	0.66	EPA 200.8	3/20/2022
113 Drinking Fountain	3/10/2022 5:26	N	5.18	2.0	0.66	EPA 200.8	3/20/2022
118 Drinking Fountain	3/10/2022 5:28	N	2.1	2.0	0.66	EPA 200.8	3/22/2022
119 Drinking Fountain	3/10/2022 5:29	N	4.79	2.0	0.66	EPA 200.8	3/22/2022
120 Drinking Fountain	3/10/2022 5:31	N	2.40	2.0	0.66	EPA 200.8	3/22/2022
137 Drinking Fountain	3/10/2022 5:32	N	10.7	2.0	0.66	EPA 200.8	3/22/2022
136 Drinking Fountain	3/10/2022 5:33	N	0.985	2.0	0.66	EPA 200.8	3/22/2022
121 Drinking Fountain	3/10/2022 5:34	N	4.98	2.0	0.66	EPA 200.8	3/22/2022
129 Drinking Fountain	3/10/2022 5:37	N	<0.66	2.0	0.66	EPA 200.8	3/22/2022
126 Drinking Fountain	3/10/2022 5:38	N	<0.66	2.0	0.66	EPA 200.8	3/22/2022
210 Water Cooler	3/10/2022 5:39	N	<0.66	2.0	0.66	EPA 200.8	3/22/2022
127 Drinking Fountain	3/10/2022 5:41	N	<0.66	2.0	0.66	EPA 200.8	3/22/2022
128 Drinking Fountain	3/10/2022 5:43	N	<0.66	2.0	0.66	EPA 200.8	3/22/2022

**Building: Evans Elementary School Lead Results - FLUSH - 2022**

Sample ID	Date/Time Collected	Flushed	Result	Reporting Limit	Method Detection Limit	Analytical Method	Date of Analysis
		(Y/N)	(ug/L)	(ug/L)	(ug/L)		
112 Drinking Fountain- Initial	3/11/2022 5:50	N	<b>2.97</b>	2.0	0.66	EPA 200.8	3/22/2022
112 Drinking Fountain- Flush	3/11/2022 5:51	Y	<b>4.66</b>	2.0	0.66	EPA 200.8	3/22/2022
115 Drinking Fountain- Initial	3/11/2022 5:55	N	<b>4.88</b>	2.0	0.66	EPA 200.8	3/22/2022
115 Drinking Fountain- Flush	3/11/2022 5:56	Y	<b>1.81</b>	2.0	0.66	EPA 200.8	3/22/2022
112 Drinking Fountain Remediation		Replace Faucet					
115 Drinking Fountain Remediation		Replace Faucet					

**Building: Jaggard Elementary School Lead Results - FLUSH - 2022**

Sample ID	Date/Time Collected	Flushed	Result	Reporting Limit	Method Detection Limit	Analytical Method	Date of Analysis
		(Y/N)	(ug/L)	(ug/L)	(ug/L)		
174 Drinking Fountain- Initial	3/10/2022 6:06	N	31.6	2.0	0.66	EPA 200.8	3/22/2022
174 Drinking Fountain- Flush	3/10/2022 6:07	Y	6.16	2.0	0.66	EPA 200.8	3/22/2022
249 Water Cooler- Initial	3/10/2022 6:10	N	1.79	2.0	0.66	EPA 200.8	3/22/2022
249 Water Cooler- Flush	3/10/2022 6:26	Y	<0.66	2.0	0.66	EPA 200.8	3/22/2022
174 Drinking Fountain Remediation	Install Lead Removing Filter						
249 Water Cooler Remediation	Replace Water Cooler						

**Building: Marlton Elementary School Lead Results - FLUSH - 2022**

Sample ID	Date/Time Collected	Flushed (Y/N)	Result (ug/L)	Reporting Limit	Method Detection Limit	Analytical Method	Date of Analysis
				(ug/L)	(ug/L)		
159 Kitchen Sink - 1- FLUSH	3/16/2022 5:16	Y	<0.66	2.0	0.66	EPA 200.8	3/24/2022
159 Kitchen Sink - 2- FLUSH	3/16/2022 5:18	Y	6.56	2.0	0.66	EPA 200.8	3/24/2022
159 Kitchen Sink - 1 Remediation	Replace Faucet						
159 Kitchen Sink - 2 Remediation	Replace Faucet						

**Building: Marlton Middle School Lead Results - FLUSH - 2022**

Sample ID	Date/Time Collected	Flushed	Result	Reporting Limit	Method Detection Limit	Analytical Method	Date of Analysis
		(Y/N)	(ug/L)	(ug/L)	(ug/L)		
156 Gym Water Fountain Girls- FLUSH	3/16/2022 5:28	Y	<0.66	2.0	0.66	EPA 200.8	3/24/2022
322 Hall APR Water Cooler - 1- FLUSH	3/16/2022 5:53	Y	<0.66	2.0	0.66	EPA 200.8	3/24/2022
323 Hall APR Water Cooler - 2- FLUSH	3/16/2022 5:54	Y	1.37	2.0	0.66	EPA 200.8	3/24/2022
324 Hall APR Water Cooler - 3- FLUSH	3/16/2022 5:55	Y	<0.66	2.0	0.66	EPA 200.8	3/24/2022
325 Hall APR Water Cooler - 4- FLUSH	3/16/2022 5:56	Y	<0.66	2.0	0.66	EPA 200.8	3/24/2022
156 Gym Water Fountain Girls Remediation		Replace Faucet					
322 Hall APR Water Cooler - 1 Remediation		Replace Water Cooler					
323 Hall APR Water Cooler - 2 Remediation		Replace Water Cooler					
324 Hall APR Water Cooler - 3 Remediation		Replace Water Cooler					
325 Hall APR Water Cooler - 4 Remediation		Replace Water Cooler					